



4705



UKCA CERTIFICATE

APPROVED BODY NUMBER 0843

UK CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 0843-CPR-1012

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: Door-Stop International Limited, Subsidiary of Premdor Crosby Limited

Address: Export Drive, Huthwaite, Nottinghamshire, NG17 6AF

Product Description: Fire Resisting Doorset

Model Reference: Door-Stop International 30 minute (fire/smoke leakage) single and dual certificated timber core doorsets with GRP facings

Places of production: Door-Stop International Limited, Subsidiary of Premdor Crosby Limited
Export Drive, Huthwaite, Nottinghamshire, NG17 6AF

Designated Standard(s): EN 16034: 2014*

* Note: EN 16034: 2014 shall be applied together with EN 14351-1: 2006+A2: 2016 and regardless of the essential characteristics listed in this certificate, the manufacturer shall declare the performance of the essential characteristics covered by EN 14351-1: 2006+A2: 2016 that are not covered by the scope of the tasks of the UK Approved Body and this certificate.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standards, under system 1/1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.

Date of 1st issue: **22nd October 2021**
Issue: **2**
Date of re-issue: **25th October 2021**

Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:

Name: David Yates
Approved Body Decision Maker



4705



UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1012

Detailed information sheet

Model Reference: FD30 Certificated Apartment Entrance Doorsets with GRP facings & PAS24-FD30 Dual Certificated Apartment Entrance Timber Doorsets with GRP facings

Type: Single acting, single leaf doorset

Description: Fire Resisting Doorset

Key Performance parameters:

| Essential Characteristic | Clause of EN 16034: 2014 | Mandates levels and/or classes |
|----------------------------------|--------------------------|--------------------------------|
| Resistance to Fire | 4.1 | See pages below |
| Smoke Control | 4.2 | S _a |
| Ability to Release | 4.3 | NPD |
| Self-closing | 4.4 | C0 |
| Durability of ability to release | 4.5.1 | NPD |
| Durability of self-closing | 4.5.2 | NPD |

Technical documentation:

UL Report: 4789883820B

Limitations on the acceptance or use of the product(s):

Installation instructions: To be used in accordance with the supplier's installation instructions.

Detailed scope of application covered by this certificate: Contained in classification reports referenced above

Date of 1st issue: **22nd October 2021**
 Issue: **2**
 Date of re-issue: **25th October 2021**

Issued by UL International (UK) Ltd., Approved Body 0843.









Signed: 
 Name: David Yates
 Approved Body Decision Maker



4705

UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1012

| Doorset style | Description | Configuration | Classification |
|---|---|---------------------------------|------------------------------------|
|  | Service cupboard FDF R – Flush skin (Open out, without closer) | Doorset only | E 30-C0Sa, EI ₁ 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Service cupboard FD R – Cottage skin (Open out, without closer) | Doorset only | E 30-C0Sa, EI ₁ 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FDF R – Flush skin (Open inwards or outwards) | Doorset only | E 30-C0Sa, EI ₁ 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD R – Cottage skin (Open inwards or outwards) | Doorset only | E 30-C0Sa, EI ₁ 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD H – 6 panel (Open inwards or outwards) | Doorset only | E 30-C0Sa, EI ₁ 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD Q – 4 panel (Open inwards or outwards) | Doorset only | E 30-C0Sa, EI ₁ 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD D (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD C (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |

Date of 1st issue: **22nd October 2021**Issue: **2**Date of re-issue: **25th October 2021**

Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:







Name: **David Yates**
Approved Body Decision Maker



4705

UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1012

| Doorset style | Description | Configuration | Classification |
|---|---|---------------------------------|----------------|
|  | Apartment doorset FD I (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD U (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD W2 (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD 56 (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD 57 (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |
|  | Apartment doorset FD 58 (Open inwards or outwards) | Doorset only | E 30-C0Sa |
| | | Doorset with glazed toplight | E 30-C0Sa |

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1st issue: **22nd October 2021**
Issue: **2**
Date of re-issue: **25th October 2021**

Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:



Name: David Yates
Approved Body Decision Maker

Page 4 of 4